



WE SERVE TO SAVE

ગુજરાતરાજ્યઅગ્નિનિવારણસેવાઓનીપ્રાદેશિકકચેરી

ગાંધીનગરરીજીયન

ગાંધીનગર | મહેસાણા | પાટણ | બનાસકાંઠા | સાબરકાંઠા | અરવલ્લી



Fire Safety Certificate (FSC) No: SFPS /R-5/50/2023

Date: 25/09/2023

FIRE SAFETY CERTIFICATE

(Form B13)

(See Sub Rule (1) Of RULE 23)

Certified that the **Samaj Seva Trust, Survey No.28/2, At-Bhiloda, Dist-Arvalli,** comprised Of Ground + 2 Floors (School) Owner/occupied By **Devang K Barot (Mobile No.- 9586937567)** of have complied with the fire prevention and fire safety requirements in accordance with section 18 and verified by the officers concerned of Fire Service on Dt.18-09-2023 in the presence of **Pravina & Sons Fire Safety (Mobile No.-9016555238)** and that the Building(School) fit for occupancy with effect from for a period of 3 Years (**from Dt.25-09-2023 to Dt.24-09-2026**) years in accordance with rules and subject to compliance of any specific laid by the issuing officer.

Place: - Gandhinagar

Issued Dt: 25-09-2023.

Challan No. (2500)- 276

Challan No. (1000)- 277



[Signature]
25/09/23

Regional Fire Officer

Gujarat State Fire Prevention Services

Gandhinagar Region

Endorsement

The Fire Safety Certificate issued By Fire Service Stand Cancelled and Annulled Due To

.....

Regional Fire Officer

Gujarat State Fire Prevention Services

Gandhinagar Region


બ્લોક - ૯, ગ્રાઉન્ડફ્લોર, ઉદ્યોગભવન, ધ - ૪, સેક્ટર૨૧૧, ગાંધીનગર, ગુજરાત - ૩૮૨૦૧૦

વેબ - <https://gujfiresafety.com.in> | ઈ-મેલ - rfo-sfps-anr@gujarat.gov.in | ફોન - ૦૭૯૨૩૨ ૩૮૮ ૭૨ / ૭૩

Viswakarma fire safety & Solution

All Types Of Supplier & Re-filling Of Fire Extinguishers Bottles & ISI safety equipments

Address : Godown No.: 60 Behind Dena Gramin Bank, Vijaynagar Cross road, Mathasur (S.K) Gujarat 383430
Mo, 9016555238



Ref : VFS/ /B6/22/23IN

Date: 20 / 09 / 2023

Certificate for Fire Extinguisher Equipment

Dear sir,

We here by refilling / new of Co2 Type/ DCP (ABC)/W/T Co2 60GSM Cartridge for capacity with respect to mention below detail. All detail are true with one year warranty period, this certificate valid for year to the respect Dry Chemical powder & pressure.

In case of any damage within the warranty time period M/S Vishwakarma fire safety will replace the equipment or free service depends on issue. We here by validate the refilling service warranty for one year.

USER : Ganraj Jeeva Purohit, Biloda.

Details :-

Billing No. :

Type : Co2 / ABC (Dry Chemical Powder) W/T 60 GSM Cartridge/ BC Type (DCP)

JOB Type :

New Purchase / Refilling

CAPACITY For (Dry Chemical Powder) : 02 Kg / 04Kg / 05Kg / 06 Kg / 09Kg / 10kg 02 No.

CAPACITY For (Co2 Type) : 01 Kg / 02Kg / 4.5Kg / 06Kg 02 No.

CAPACITY For (Co2 Cartridge): 60 GSM / 150GSM / 200 GSM / 300 GSM

NEXT DUE DATE ON :

20/09/2024.

1.	Co2- Type (Fire Extinguisher Equipment)	4.5Kg/2Kg	VFS/Co2/09/01/23IN.
2.	Dry Chemical Powder ABC/BC Type Extinguisher	4.5Kg/2Kg 5Kg/6Kg 9Kg/10Kg	VFS/ABC/09/01/23IN.
3	W/T Fire Extinguisher Equipment)	60 GSM	



VISHWAKARMA FIRE SAFETY & SOLUTION (VFSS)

Address : Godown no : 60 Behind Dena Gramin Bank, Vijaynagar cross road, Mathasur (S.K), Gujarat
Add: Workshop no : Sarvoday Mohollo, Near Ambetkar Chok, Opp. Water Tank, Mehsana-384002



GeM
Government
e Marketplace

WILLS SOLUTION

All Type of Supplier & refilled of Fire extinguisher Equipment , Dealing with fire system installation

Address: 58, Jawanpura market, Bus Station Road, Idar(Sabarkantha) (Guj)- 383410

GSTIN: 24EHVPD2780F1ZR Contact : 9016555238 Mail ID: yfss777hmt@gmail.com

Report No : HP-105/09/23IN

Date : 20.09.2023

To,

Samaj Seva Trust , Bhiloda

Opp, Bhiloda Police Station

Dist: Arvalli

State: Gujarat

THIS IS CERTIFY THAT HP TESTING AS PER IS: 15683 BY US AS FOLLOWING

The aforesaid extinguisher's cylinder has been tested hydraulically 30KG/Cm2 internal pressure and following description of testing

FIRE EXTINGUISHERS HP TEST REPORT						
Sr No	Description of fire extinguisher	QTY	Capacity	Hydro press Date	Hydro Press Due Date	Remarks
1	DRY Chemical Powder (ABC TYPE FIRE EXTINGUISHER EQUIPMENT)	6Nos	5Kg	20.09.2023	20.09.2026	OK

Total Number of Fire Extinguisher Equipment = 6 Nos

GSTIN NO: (24EHVPS2780F1ZR)
WILLS SOLUTION

Name(Inspection Done By)
Signature :



Godown Address : At & PO. Mohanpura, Ta. Idar, Dist. Sabarkantha 383430 (Gujarat)

